

(256) SUBSECTION 31.2.1

ADD NEW SECTION 31.2.1 AFTER SECTION 31.2 AS FOLLOWS:

- (I) A COPY OF THE FACILITY'S NATURAL WOOD WASTE RECYCLING FACILITY OR COMPOSTING PERMIT APPLICATION, INCLUDING THE OPERATIONS PLAN AND THE EMERGENCY PREPAREDNESS MANUAL, SHALL BE SENT TO THE AHJ FOR REVIEW AND RECOMMENDATIONS TO THE DEPARTMENT OF PLANNING AND ZONING.
- (II) A COPY OF THE INFORMATION REQUIRED BY PARAGRAPH (I) OF THIS SUBSECTION SHALL BE SUBMITTED TO THE AHJ WITH EACH STATE PERMIT RENEWAL (5 YEAR RENEWALS).

(257) SUBSECTION 31.3.4.3.2.1

ADD NEW SUBSECTION 31.3.4.3.2.1 AFTER SUBSECTION 31.3.4.3.2 AS FOLLOWS:

THE PRIMARY ROAD SHALL:

- (I) BE KEPT ADEQUATELY CLEAR IN ORDER TO PROVIDE ACCESS THE PROCESSING/STORAGE AREA ; AND
- (II) BE PAVED OR CONSTRUCTED SO AS TO PROVIDE ALL WEATHER, YEAR ROUND, ACCESS BY FIRE APPARATUS WITH A WEIGHT OF 75,000 GVW.

(258) SUBSECTION 31.3.6.2.2

ADD NEW PARAGRAPH 9 AFTER PARAGRAPH 8 AS FOLLOWS:

A PILE CONTAINING LEAVES AND OTHER EXTRANEIOUS OR HOGGED MATERIAL, SUCH AS A WHOLE TREE CHIP PILE, SHALL BE TURNED OR RECLAIMED EVERY THREE MONTHS.

(259) SUBSECTION 31.3.6.3.1

DELETE THIS SUBSECTION AND SUBSTITUTE THE FOLLOWING:

PILES MAY NOT EXCEED 18 FEET IN HEIGHT, 50 FEET IN WIDTH, AND 350 FEET IN LENGTH. TWO PILES SHALL BE DIVIDED BY A FIRE LANE HAVING AT LEAST 25 FEET OF CLEAR SPACE AT THE BASE OF THE PILE.

(260) SUBSECTION 31.3.6.3.2

DELETE THIS SUBSECTION.

(261) SUBSECTION 31.3.6.3.2.1

DELETE THIS SUBSECTION.

(262) SUBSECTION 31.3.6.3.2.2

DELETE THIS SUBSECTION.

(263) SUBSECTION 31.3.6.3.2.3

DELETE THIS SUBSECTION.

(264) SUBSECTION 31.3.6.3.5.1

ADD NEW SUBSECTION 31.3.6.3.5.1 AFTER SUBSECTION 31.3.6.3.5 AS FOLLOWS:

IF THE OPERATION IS LOCATED OUTSIDE OF A MUNICIPAL WATER SUPPLY THE FOLLOWING WILL APPLY:

- (I) THE AHJ WILL REQUIRE A RELIABLE CERTIFIED WATER SUPPLY SYSTEM WITH THE CAPABILITY TO SUPPLY 1000 GALLONS PER EVERY 10,000 CUBIC FEET OF PILE. THE SUPPLY SYSTEM MUST BE CAPABLE OF PRODUCING A MINIMUM OF 250 GPM (PREFERRED IS 500GPM) FOR AT LEAST 2 HOURS.
- (II) THE MULCH/WOOD PROCESSING OPERATION SHALL HAVE A FIRE STATION LOCATED WITHIN 5 TRAVEL MILES OF THE LOCATION.
- (III) IF THE WATER SUPPLY IS STATIC IT IS TO BE CERTIFIED BY AN ENGINEER AND CAPABLE TO SUPPLY THE AMOUNT REQUIRED BY PARAGRAPH (I) OF THIS SUBSECTION. IF THE WATER SUPPLY IS BELOW THE MINIMUM AMOUNT, THEN THE SUPPLY MUST BE CAPABLE OF AT LEAST 30,000 GALLONS AT ALL TIMES. THE MAXIMUM SIZE OF WATER SUPPLY NEEDED MAY BE BASED ON THE PROPOSED OPERATION AND APPROVED BY THE AHJ.
- (IV) BASED ON THE AMOUNT OF MATERIAL ON SITE, OTHER PROVISIONS SUCH AS SPRINKLERS, PRE-PIPED SYSTEMS, OR CONSTANT MONITORING OF THE PILE MAY BE REQUIRED.

(265) SECTION 33.1.2

DELETE THIS SECTION AND SUBSTITUTE THE FOLLOWING:

WHERE REQUIRED, A PERMIT FOR OUTSIDE STORAGE SHALL BE OBTAINED FROM THE MARYLAND DEPARTMENT OF THE ENVIRONMENT. A PERMIT FROM THE AHJ IS REQUIRED FOR THE STORAGE OF 500 TIRES OR MORE. A PERSON MAY NOT STORE MORE THAN 5,000 TIRES.

(266) SECTION 33.1.12

ADD NEW SECTION 33.1.12 AFTER SECTION 33.1.11 AS FOLLOWS: