

Amendment 1 to Council Bill No. 54-2020

BY: The Chairperson at the request
of the County Executive

Legislative Day 15
Date: November 2, 2020

Amendment No. 1

(Based on feedback from the Board of Electrical Examiners, this amendment clarifies when certain electrodes shall be used.)

1 On page 2, strike lines 18 through 23, inclusive and in their entirety, and substitute:

2 “(6) SECTION 250.50. GROUNDING ELECTRODE SYSTEM.

3 AFTER THE SECOND SENTENCE THAT ENDS “INSTALLED AND USED.” INSERT:

4 “FOR BUILDINGS OR STRUCTURES FED WITH ELECTRIC POWER WHERE THE ELECTRODE AS

5 DESCRIBED IN 250.52(A)(3)(1) DOES NOT EXIST, AN ELECTRODE THAT COMPLIES WITH

6 250.52(A)(3)(1) OR 250.52(A)(3)(2) SHALL BE INSTALLED AND USED.”.

7

ADOPTED November 2, 2020
FAILED _____
SIGNATURE Deane Schwartz Jones