ESSERGY SYSTEMS GROUP Building Performance with Energy		Typ Range ⁽¹⁾ IESNA Values
SPACE	USE	RANGE
Auditoriums	Assembly	10 to 20
	Social Activity	5 to 10
Lobby Areas for waiting		10 to 20
Lobby Areas for writing		20 to 50
Lounges and Reading Rooms		20 to 50
Conference rooms	Meeting	20 to 50
Corridors		10 to 50
Offices		30 to 50
Open Offices		20 to 50
Open Offices with Task Lighting		20 to 50
Classrooms		50 to 100
Lecture rooms, shops, study halls		100 to 200
Library Reading Areas		20 to 50
Library Stacks		20 to 50
Gymnasiums		20 to 50
Laboratories		50 to 100
Prision Yards		2 to 5
Prison Cells		25 to 35
File rooms		20 to 50
Mail rooms		50 to 100
Stairways		10 to 20
Computer rooms		10 to 20
Exterior Flood lighting		2 to 5
Closets		2 to 5
Retail Sales Area		100 to 200
Restrooms		10 to 20
Warehouse		10 to 20
Elevators		10 to 20

⁽¹⁾ The range presented here are representative recommendations for the space type and typical associated visual activities. Actual lighting levels may vary depending on the specific space characteristics.

Note: Please refer to IESNA for spaces not listed here